

BID/ RFP ADDEDUM
DATE: 1/23/2023
BID/RFP No: 2023-02
BID/ RFP TITLE: Los Banos CDC
DSA FILE No.: 24-C1
DSA APPL No. 02-120552

MERCED COMMUNITY COLLEGE DISTRICT
Chuck Hergenraeder, Director, Purchasing and Risk Management
3600 M Street, Merced, California 95348-2898
Telephone: 209/384-6300 • Fax: 209/384-6310
Email: Charles.Hergenraeder@mccd.edu

ADDENDUM 2

This addendum contains clarification and additional information, which modifies the conditions of the above referenced BID/RFP as follows:

The following additions, deletions and revisions to the plans, specifications and Addenda shall become a part of the plans and specifications. It is the responsibility of the General Contractor to submit the information contained in this addendum to all subcontractors and suppliers. The Bidder shall acknowledge receipt of the Addendum in the Bid Proposal. (Addendum number of pages: 1 total).

CLARIFICATIONS:

1 - 01: RFI – 01: There are two different manufactures with two different plans in the general plan set. Which manufacturer is providing the buildings?

Response: There are 2 different plans because one is the original PC Approved record drawings, by AMS. The 'Global Modular' set includes modifications to the original drawings. The site contractor will be coordinating with Global Modular on this project.

1 - 02: RFI – 02: Who is in charge of Foundation and Rat Slabs for this project, on-site contractor or building contractor?

Response: All foundation and rat slab work is to be by the Site contractor, please include this scope in the site contract bid.

1 - 03: RFI – 03: On drawing F0.0 General Note #8 has grates at 1-3/16" on center this is not typical for schools we usually go 11/16" on centers which covers ADA or 7/16" on center to cover ADA and high heel use please advise.

Response: Grates proposed with spacing that is CBC accessible compliant and ADA compliant will be accepted.

DRAWINGS & SPECIFICATIONS:

No Changes

END OF ADDENDUM NO. 02

SPECIAL NOTE:

It is the responsibility of each Bidder to acknowledge all addenda by signing below and submitting a copy of each addendum with their respective bid.

I HAVE READ AND UNDERSTAND THESE MODIFICATIONS TO THE ABOVE BID:

All other bidding contract and construction drawing documents, stipulations, dated and times remain unchanged, in full effect and by reference become a part of this addendum.